

Alfred Water Purifier Specialist Pte Ltd
5 Soon Lee Street
#04-11 Pioneer Point
Singapore 627607

The following sample was submitted and identified by the client as:


Description : (1) Alfred Platinum Water Filtration System

Sample Receiving Date : 13 August 2015
Date of Test/s Performed : 14 August 2015

Test Results : Please refer to next page(s)

Conclusion : Based solely on the attached chemical and physical analysis, we are of the opinion that the sample **complies** with WHO Guideline values for Drinking Water (2011).

Signed for and on behalf of
SGS Testing & Control Services Singapore Pte Ltd



Y C Tham (Ms)
Laboratory Manager

Test Location: 3 Toh Tuck Link, #01-02, Singapore 596228

This document is issued by the Company subject to its General Conditions of Service accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested *and such sample(s) are retained for 30 days only.*

Test Results:

Test	Method APHA	Results	WHO Guideline Values (2011)
		(1)	
Chemical & Physical Analysis:	APHA		
Colour (Hazen Unit)	2120B	<5	15
Turbidity (NTU)	2130B	0.3	5
pH @ 21.4°C	4500-HB	7.5	No guideline value
Taste	-	Unobjectionable	Unobjectionable
Odour	-	Unobjectionable	Unobjectionable
Fluoride (F ⁻), mg/L	4110B	0.6	1.5
Nitrate (NO ₃ ⁻), mg/L	4110B	0.3	50
Total Dissolved Solids, mg/L	2540C	129.0	1000
Total Alkalinity (as CaCO ₃), mg/L	2320B	40.0	No guideline value
Total Hardness (as CaCO ₃), mg/L	2340C	63.8	No guideline value
Chloride (Cl ⁻), mg/L	4110B	40.4	250
Sulphate (SO ₄ ²⁻), mg/L	4110B	23.6	250
Phosphate (PO ₄ ²⁻), mg/L	4110B	0.6	No guideline value
Silica (SiO ₂), mg/L	3120B	7.4	No guideline value
Iron (Fe), mg/L	3120B	<0.01	0.3
Manganese (Mn), mg/L	3120B	<0.05	0.4
Copper (Cu), mg/L	3120B	<0.01	2
Aluminium (Al), mg/L	3120B	<0.1	0.2
Residual Chlorine (as Cl, Total), mg/L	Lovibond	<0.1	5.0
Bacteriological Characteristics:			
E.Coli, cfu/100mL (35°C/24hrs)	9222G	< 1	< 1

Samples Container Description:

Sample was received in sterile and non-sealed glass bottle which was collected from the client premise and tested as it is.

*****End of report*****

Test Location: 3 Toh Tuck Link, #01-02, Singapore 596228

This document is issued by the Company subject to its General Conditions of Service accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained here on reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

SGS Testing & Control Services Singapore Pte Ltd | 3 Toh Tuck Link #01-02/03 Singapore 596228 t +65 6379 0111 f+65 6777 2914 www.sgs.com